

Log No. 88147
 Permit No. _____
 Basin 106

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50906

1. OWNER Paul Huddleston ADDRESS AT WELL LOCATION TOPAZ HEIGHTS EAST SIDE LANE
 MAILING ADDRESS 1255 Slate Rd Wellington NV, 89444 3.5+ miles NORTH OF NV. STATE LINE
 2. LOCATION 05W 1/4 NW 1/4 Sec. 8 T. 9 N. R. 23 E Douglas County
 PERMIT NO. 0923-08-000-0017 Parcel No. _____ Subdivision Name Topaz Heights
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SOIL gravel		0	65	65
COARSE SAND				
CLAYEY SAND		65	185	120
COARSE SAND	X	185	205	20
CLAY with some SAND		205	280	75
BROKEN ROCKS with small gravel + coarse sand	X	280	330	50

8. WELL CONSTRUCTION
 Depth Drilled 330 Feet Depth Cased 330 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 330 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>+2</u>	<u>190</u>
<u>6 5/8</u>		<u>.188</u>	<u>210</u>	<u>290</u>

Perforations:
 Type perforation factory slot
 Size perforation 3/32" x 3"
 From _____ feet to _____ feet
 From 190 feet to 210 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From 290 feet to 330 feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 330 feet

9. WATER LEVEL
 Static water level 202' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

Date started 9-11-02
 Date completed 9-18-02

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>5</u>		<u>3.5 hours</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Sierra Nevada Drilling + Pump
 Address 3540 Green Acres Dr Carson City NV 89205
 Nevada contractor's license number 52078
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1902
 Division of Water Resources, the on-site driller.
 Signed John B. O'Neil
 driller performing actual drilling on site or contractor
 Date 10-5-02