WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88155
Permit No.
Basin 099

NOTICE OF INTENT NO. 47930

1. OWNER OTTO Olfjer
MAILING ADDRESS 12671 Rough & Ready CA
ADDRESS AT WELL LOCATION 15505 Frontier Rd Reno NV 89506

2. LOCATION NE ¼ NE ¼ Sec. 10 T. 23 N/S R. 18 E. Washoe County
PERMIT NO. (Issued by Water Resources) 078-201-31 (Parcel No.) Sierra Rancho (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	110	110
Rocks		110	118	18
Hard Rock		118	350	232
Clay		350	355	5
Hard Rock		355	406	51
Br Sand		406	408	2
Br Clay		408	450	42
Bl Clay		450	487	37
Rock Frack	"	487	506	19
Br Clay		506	515	9
Rock Frack	"	515	580	65

Date started 8/29/02 19
Date completed 9/20/02 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40+	260'	6

8. WELL CONSTRUCTION
Depth Drilled 580 Feet Depth Cased 580 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	200 Feet
8 3/4 Inches		200 Feet	580 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	3/16	2+	580

Perforations:
Type perforation Saw Slot
Size perforation 3/16
From 580 feet to 480' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 580 feet

9. WATER LEVEL
Static water level 88 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature NA °F Quality NA

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Olenski Drilling & Pump Co (Contractor)
Address 15045 Red Rock Rd (Contractor)
Reno NV 89506
Nevada contractor's license number issued by the State Contractor's Board 50343
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1656
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 10/7/02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627