WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88165
Permit No.
Basin 107

NOTICE OF INTENT NO. 47909

1. OWNER J. D. SHRAKE
MAILING ADDRESS 24405 LAKME AVE. WILMINGTON, CA. 90744
ADDRESS AT WELL LOCATION 47 WALTERS LN WELLINGTON, NV. 89444

2. LOCATION SW 1/4 NE 1/4 Sec. 23 T. 11 N N/S R. 23 E LYON County
PERMIT NO. Issued by Water Resources | Parcel No. 10-321-07 | Subdivision Name SWAKIE

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[X] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL/SANDY LOAM	NO	0	4	4
HARD PAN/SM. GRAVEL	NO	4	16	12
COARSE SAND	NO	16	33	17
FINE SAND	NO	33	40	7
COASE SAND	NO	40	45	5
BROWN CLAY	NO	45	52	7
SANDY BWN CLAY	NO	50	72	22
COARSE SAND/SM. GRAVEL	YES	72	90	18
COARSE SAND	YES	90	125	35
COARSE SAND/SM. GRAVEL	YES	125	135	10

Date started FEB. 28 2003
Date completed MAR. 10 2003

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
28	20	6

8. WELL CONSTRUCTION
Depth Drilled ..... Feet Depth Cased ..... Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 5/8 Inches	0 Feet	60 Feet
6 1/2 Inches	60 Feet	135 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625		.188	+1.5	135

Perforations:
Type perforation FACTORY SAW SLOT
Size perforation 1/8" X 4" X 4" OC / 4 ROWS
From 135 feet to 105 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 60'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [ ] Yes [X] No
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 50' feet below land surface
Artesian flow 0 G.P.M. 0 P.S.I.
Water temperature 48 °F Quality EXELENT

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDMUND MILLER DRILLING
Contractor
Address BOX 92 SMITH NV. 89430
Contractor
BILL SUTTON - DRILLER ON SITE
Nevada contractor's license number issued by the State Contractor's Board 32166-A
Nevada driller's license number issued by the Division of Water Resources, the on site driller 2232
Signed Bill Sutton
By driller performing actual drilling on site or contractor
Date 03-10-03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627