WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.310

OFFICE USE ONLY
Log No. 88168
Permit No.
Basin 049

NOTICE OF INTENT NO. 44988

1. OWNER Dan Hamphill
MAILING ADDRESS 374-15 KITTERIDGE
ELKO, NV 89801
ADDRESS AT WELL LOCATION None

2. LOCATION SE ¼ SW ¼ Sec. 35 T. 35 ☒S R. 55 E. ELKO County
PERMIT NO. N/A (Issued by Water Resources) | LOT 8, BLK 62, UNIT #5 (Parcel No.) | MEADOW VALLEY RANCHOS (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil		0	1	1
Cobbles & clay		1	7	6
Gravel & clay		7	152	145
Sandy clay		152	210	58
Sand		210	217	7
Sand w/water	✓	217	218	1
Sand w/clay streaks	✓✓	218	258	40
Loose sand	✓✓	258	259	1
Clay		259	260	1
T.D. 260				

Date started 9-10-02, ~~19~~
Date completed 9-23-02, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
200	15	2hrs

8. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 26X0 WF 3504 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
~~12~~ 10 Inches		0 Feet	50 Feet
8 Inches		50 Feet	210 Feet
6 Inches		210 Feet	260 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	260

Perforations:
Type perforation Torch cut
Size perforation
From 238 feet to 252 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 210 feet

9. WATER LEVEL
Static water level 190 feet below land surface
Artesian flow No G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name MUTH DRILLING CO (Contractor)
Address 203 PINE ST (Contractor)
ELKO, NV 89801
Nevada contractor's license number issued by the State Contractor's Board 10819
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632
Signed James V. Muth (By driller performing actual drilling on site or contractor)
Date 10-2-02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627