WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88183
Permit No.
Basin 091

NOTICE OF INTENT NO. 504116

1. OWNER ALAN GLEN
MAILING ADDRESS P.O. BOX 8460
Incline Village, Nevada 89452

ADDRESS AT WELL LOCATION "Main House Well"
860 Bridge Street
Verdi, Nevada 89439

2. LOCATION NW ¼ NE ¼ Sec. 18 T 19N N/S R 18 E Washoe County
PERMIT NO. (Issued by Water Resources) 038-821-07 (Parcel No.) Verdi area (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil with gravels, boulders		0	1	1
Gravel sand, boulders some clay		1	40	39
Soft clay with gravels and sand		40	43	3
Gravel, boulders with sandy clays		43	64	21
Granite boulder		64	68	4
Gravels and boulders with sandy clays		68	92	24
Green sandy clays		92	96	4
Gray sandy clays		96	109	13
Dark brown sandy clays		109	138	29
Soft zone	X	138	144	6
Dark brown sandy clays		144	155	11
Soft zone	X	155	159	4
Gray sandy clay		159	167	8
Soft zone	X	167	172	5
Gray sandy clays		172	183	11
Soft zone	X	183	191	8
Gray sandy clays		191	217	26
Soft zone	X	217	226	9
Gray sandy clays		226	231	5
Black sticky sandy clays		231	242	11
Gray clay with gravel and boulder		242	268	26
Soft zone	X	268	271	3
Green to gray volcanic		271	290	19

Date started August 7, 2002, 20
Date completed August 13, 2002, 20

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30+		

8. WELL CONSTRUCTION
Depth Drilled 290 Feet Depth Cased 290 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9 7/8 Inches	0 Feet	290 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	290

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 145 feet to 225 feet
From 265 feet to 285 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100 feet
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 290 feet

9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow G.P.M. 30+ P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed (By driller performing actual drilling on site or contractor)
Date August 21, 2002

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627