WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88198
Permit No.
Basin 102

NOTICE OF INTENT NO. 50060

1. OWNER Jones Kathleen Edward
MAILING ADDRESS
ADDRESS AT WELL LOCATION 15065 Hoover Dr.

2. LOCATION SE ¼ NW ¼ Sec. 15 T. 18 N/S R. 26 E. Churchill County
PERMIT NO. (Issued by Water Resources) Parcel No. 006-122-67 Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☑ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	8	
Boulders		0	136	
Clay Tuff		136	171	
Gravel Boulders		171	231	
		231	324	
Sand Brown				
Clay Brown		324	351	
Sand stone	✓	351	460	

Date started 9-24
Date completed 9-29

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Produced about 2 bbls		

8. WELL CONSTRUCTION
Depth Drilled 460 Feet Depth Cased 460 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	60 Feet
8 3/4 Inches	60 Feet	400 Feet
6 Inches	400 Feet	460 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	3/16	+1	400
6"	10.00	3/16	390	460

Perforations:
Type perforation Mill Slot
Size perforation 1/4" x 3 Long
From 300 feet to 320 feet
From 340 feet to 360 feet
From 380 feet to 400 feet
From 390 feet to 460 feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0—50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From 50 feet to 400 feet

9. WATER LEVEL
Static water level 220 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc (Contractor)
Address PO Box 544 (Contractor)
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board 031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1807
Signed (By driller performing actual drilling on site or contractor)
Date 9-30-02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

USGS COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88198
Permit No.
Basin 102

NOTICE OF INTENT NO. 50060

1. OWNER Jones Kathleen Kelleher
MAILING ADDRESS
ADDRESS AT WELL LOCATION 15065 Hoover Dr.

DATABASE AMENDED

2. LOCATION SE ¼ ~~NW~~ NE ¼ Sec. 15 T. 18 N/S R. 26 E. Churchill County
PERMIT NO. (Issued by Water Resources) 006-122-~~67~~ 68 (Parcel No.) 102 N18E26 15ADAA 01 (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☑ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	8	
Boulders		0	136	
Clay Tan		136	171	
Gravel Boulders		171	231	
		231	324	
Sand Stone				
Clay Brown		324	351	
Sand stone	✓	351	460	

RECEIVED 02 OCT 28 PM 1:42 STATE ENGINEERS OFFICE

Date started 9-24 2002
Date completed 9-29 2002

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Produced about 2 GPM		

8. WELL CONSTRUCTION
Depth Drilled 460 Feet Depth Cased 460 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	60 Feet
8 3/4 Inches	60 Feet	400 Feet
6 Inches	400 Feet	460 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	3/16	+1	460
5"	10.00	3/16	390	460

Perforations:
Type perforation Mill slot
Size perforation 1/4 x 3 Long
From 300 feet to 320 feet
From 340 feet to 360 feet
From 380 feet to 400 feet
From 390 feet to 460 feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From 50 feet to 400 feet

9. WATER LEVEL
Static water level 220 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc (Contractor)
Address PO Box 599 (Contractor)
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board 031841
Nevada driller's license number issued by the Division of Water Resources, the on site driller 1877
Signed [signature] By driller performing actual drilling on site or contractor
Date 9-30-02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

1/06/04

~~KELLEHER~~ - SPOKE W/ MRS KELLEHER

SAME CONDITION AS IN PHOTOS

OCT NOV - 2002 - PAID 7000 - STIP AGREE W/ BLAIN

* OSG STILL LOOSE +

CAN HEAR DIRT FALLING DOWN BACKSIDE WHEN MOVED CASING