

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 88204
 Permit No. _____
 Basin. 044
 NOTICE OF INTENT NO. 40219

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Anglo Gold ADDRESS AT WELL LOCATION Anglo Gold
 MAILING ADDRESS HC-31 Box 78 ELKO, NV, 89801 Jerritt Canyon

2. LOCATION NE 1/4 NW 1/4 Sec 17 T. 40 N/S R. 54 E ELKO County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE Injection
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>hard limestone</u>		<u>0</u>	<u>225'</u>	
<u>broken water limestone</u>	<u>10G.P.M.</u>	<u>225'</u>	<u>230'</u>	
<u>limestone</u>		<u>230'</u>	<u>550'</u>	
<u>broken water limestone</u>	<u>20G.P.M.</u>	<u>550'</u>	<u>570'</u>	
<u>limestone</u>		<u>570'</u>	<u>1060'</u>	
<u>broken limestone</u>	<u>1000'</u> <u>30G.P.M.</u>	<u>1060'</u>	<u>1080'</u>	

8. WELL CONSTRUCTION

Depth Drilled 1080 Feet Depth Cased 1080 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>12 1/2</u>	<u>0'</u>	<u>50'</u>	<u>50'</u>
<u>10 1/2</u>	<u>50'</u>	<u>770'</u>	<u>770'</u>
<u>10 1/2</u>	<u>770'</u>	<u>1080'</u>	<u>1080'</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/4</u>	<u>12.25</u>	<u>.188</u>	<u>0</u>	<u>1080</u>

Perforations:
 Type perforation vert. slot
 Size perforation .125
 From 600 feet to 1080 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 500 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 350' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality Clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WARD WEAVER Contractor
 Address 2305 Last Chance Rd. Contractor
ELKO, NV. 89801
 Nevada contractor's license number issued by the State Contractor's Board 0030630
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1676
 Signed Ward Weaver
 By driller performing actual drilling on site or contractor
 Date 1-25-02

Date started 10-15-02
 Date completed 10-21-02

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>80</u>		