

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 88210
 Permit No. 102
 Basin 102
 NOTICE OF INTENT NO. 48256

1. OWNER James Dolan ADDRESS AT WELL LOCATION 1295 E. Anklelope Silver Springs, NV. 89429
 MAILING ADDRESS _____
 2. LOCATION NE 1/4 SW 1/4 Sec. 19 T. 17 N/S R. 25 E Lyon County
 PERMIT NO. 17-423-15
 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other drill

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand</u>		<u>0</u>	<u>16</u>	
<u>Sand Gravel</u>		<u>16</u>	<u>47</u>	
<u>Clay Turb</u>		<u>47</u>	<u>81</u>	
<u>Sand Gravel</u>		<u>81</u>	<u>140</u>	

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 inches To 140 Feet
 _____ inches _____ Feet _____ Feet
 _____ inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.00</u>	<u>3/16</u>	<u>1</u>	<u>20</u>
<u>6 5/8</u>	<u>9.00</u>	<u>5/16</u>	<u>20</u>	<u>140</u>

Perforations:
 Type perforation grill saw
 Size perforation 1 1/4 x 6.0 in. 5/16 in. S
 From 170 feet to 140 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 0-50 _____
 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level: 57 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 9-17
 Date completed 9-18

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>Produce about 60 GPM</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Leach Drilling Inc Contractor
 Address 10 Box 579 Silver Springs NV 89429 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0031841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 9-19-02