WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No: 88227
Permit No.
Basin 101

NOTICE OF INTENT NO. 51005

1. OWNER NEVADA PANELS & GATES
MAILING ADDRESS 7945 RENO HWY
FALLON, NV 89406

ADDRESS AT WELL LOCATION 7945 RENO HWY

2. LOCATION NW 1/4 NW 1/4 Sec. 24 T. 19 N/S R 27 E CHURCHILL County
PERMIT NO. 66542 Issued by Water Resources
001-271-42 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
BROWN SAND		1	19	18
BROWN CLAY		19	28	9
BROWN SAND		28	50	22
BROWN CLAY		50	60	10
GREY SAND		60	80	20
GREY CLAY		80	85	5
GREY SILT/SAND		85	95	10
GREY GRAVEL		95	120	25
GREY CLAY		120	124	4
BROWN SAND	X	124	135	11

Date started 6/20/2002 , 19__
Date completed 10/23/2002 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50+		1 HOUR

8. WELL CONSTRUCTION
Depth Drilled 135 Feet Depth Cased 135 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	100	Feet
6 1/8	Inches	100	Feet	135	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	135

Perforations:
Type perforation MACHIUNE SLOT
Size perforation .080
From 128 feet to 133 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured

Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 15'11" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WELSCO CORP. Contractor
Address P. O. BOX 888 Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed By driller performing actual drilling on-site or contractor
Date 11/5/2002

USE ADDITIONAL SHEETS IF NECESSARY