

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 51013

1. OWNER PERALDO BROS. ADDRESS AT WELL LOCATION 4305 PERALDO LANE
MAILING ADDRESS 4305 PERALDO LANE
FALLON, NV 89406

2. LOCATION NE 1/4 NW 1/4 Sec. 2 T 20 R 19 N/S R 29 E CHURCHILL County
PERMIT NO. _____ Issued by Water Resources 7-311-03 Parcel No. _____
Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
BROWN SAND		1	10	9
BROWN CLAY		10	12	2
BROWN SILT		12	25	13
BROWN CLAY		25	35	10
GREY SILT/CLAY		35	50	15
GRAY CLAY		50	75	25
BROWN SILT/SAND		75	85	10
GREY CLAY		85	100	15
GREY SAND		100	130	30
GREY CLAY		130	150	20
GREY SAND		150	160	10
GREY CLAY		160	180	20
FRACTURED BASALT	X	180	190	10

8. WELL CONSTRUCTION
Depth Drilled 190 Feet Depth Cased 190 Feet

HOLE DIAMETER (BIT SIZE)
From 0 Feet To 50 Feet
10 3/4 Inches
From 50 Feet To 190 Feet
6 1/4 Inches

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>+2</u>	<u>190</u>

Perforations:
Type perforation MACHINE SLIT
Size perforation .080

From <u>184</u> feet to <u>188</u> feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No
Depth of Seal 50
Placement Method: Pumped Poured
Seal Type: Neat Cement Cement Grout Concrete Grout

Gravel Packed: Yes No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 16'1" feet below land surface
Artesian flow _____ G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. Contractor
Address P. O. BOX 888 Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed [Signature] By driller performing actual drilling on-site or contractor
Date 8/6/2002

Date started 7/19/2002, 19____
Date completed 7/20/2002, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50+</u>		<u>1 HR</u>