WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88254
Permit No.
Basin 094

NOTICE OF INTENT NO. 39886

1. OWNER Jim and Terry Sjoberg
MAILING ADDRESS 465 Rosetta Stone Dr.
Reno, NV

ADDRESS AT WELL LOCATION Ruby Hill Road
Reno, NV

2. LOCATION NE ¼ SW ¼ Sec. 35 T. 23 (N/S) R. 19 E. Washoe County
PERMIT NO. n/a (Issued by Water Resources) 079-530-18 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Decomposed Granite		0	34	
Gray Granite		34	484	
Brown DG		484	502	
Gray Granite		502	583	
Green Rock		583	590	
Gray Granite		590	620	

RECEIVED
02 NOV 25 PM 12:55
STATE ENGINEER'S OFFICE

Date started 8/20/02, 19
Date completed 9/14/02, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	11	620	4 hrs

8. WELL CONSTRUCTION
Depth Drilled 625 Feet Depth Cased 625 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼"	Inches	0 Feet	17 Feet
10	Inches	17 Feet	55 Feet
8½"	Inches	55 Feet	625 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	14	.188	-1	625

Perforations:
Type perforation mill slot
Size perforation 1/16 x 3
From 360 feet to 420 feet
From 424 feet to 625 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60 feet to 625 feet

9. WATER LEVEL
Static water level 511' feet below land surface
Artesian flow none G.P.M. none P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name MILLER & SONS DRILLING COMPANY (Contractor)
Address P.O. Box 8056 (Contractor)
Reno, NV 89507
Nevada contractor's license number issued by the State Contractor's Board 37915
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418
Signed Bruce Miller (By driller performing actual drilling on site or contractor)
Date 10-10-02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627