WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88256
Permit No.
Basin 173-A

NOTICE OF INTENT NO. 42530

1. OWNER Twin Springs Ranch
MAILING ADDRESS HC 74 Box 1100 Tonopah NV 89049
ADDRESS AT WELL LOCATION 4 miles East of milemarker #19 SR 375 Railroad Valley

2. LOCATION NE ¼ SE ¼ Sec. 22 T. 2 N/S R. 53 E. NYE County
PERMIT NO. 37L-21315 (Issued by Water Resources) 156-35 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☒ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty clay		0	115	115
Sand-Gravel-bolders	X	115	230	115
Clay	20	230	250	20

Lost circulation at 140
Drilled blind 140 to 170'
80% Return after 170'

RECEIVED
02 NOV 22 AM 11:03
STATE ENGINEERS OFFICE

Date started 10-15-02, 20
Date completed 10-17-02, 20

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
14	27	4

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		Sch 40	0	250

Perforations:
Type perforation Saw cut
Size perforation 1/8" x 6"
From 130' feet to 150 feet
From 170 feet to 190 feet
From 210 feet to 250 feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: [illegible]
Seal Type: ☒ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ [illegible]
From 100 [illegible] eet

9.
Static water level [illegible] surface
Artesian flow [illegible] P.S.I.
Water temperature [illegible]

10. DRILLER
This well was drilled under my supervision [illegible] true to the best of my knowledge.
Name Davis Drilling and Pumps (Contractor)
Address HC 61 Box 54 Hiko NV 89017 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0028966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed [illegible] (By driller performing actual drilling on site or contractor)
Date 10-31-02

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627