WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88274
Permit No.
Basin Ø49

NOTICE OF INTENT NO. 45462

1. OWNER MAGGIE CREEK RANCH
MAILING ADDRESS P.O. BOX 2010
ELKO, NV 89803

ADDRESS AT WELL LOCATION

2. LOCATION NE 1/4 NE 1/4 Sec. 23 T 33N N/S R 53E E ELKO County
PERMIT NO. 68174 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [X] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
LOAM		1	7	6
LIGHT CREAM COLORED		7		
CLAY MIXED WITH GRAVEL			535	528
BROKEN FORMATIONS OF	X	535		
CLAY AND SHALE/GRAVEL			546	11

RECEIVED 02 JUL 22 AM 11:44 STATE ENGINEERING OFFICE

Date started 6/5/2002, 19__
Date completed 6/13/2002, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	25		3.5

8. WELL CONSTRUCTION

Depth Drilled 546 Feet Depth Cased 546 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	546	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+2	546

Perforations:
Type perforation MILL SLOT
Size perforation 3/16 X 3
From 525 feet to 546 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 51
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 51 feet to 546 feet

9. WATER LEVEL
Static water level 500 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SHAREL C. FERTIG SR., DBA FERTIG DRILLING CO.
Contractor

Address P.O. BOX 525
Contractor

ELKO, NEVADA 89803

Nevada contractor's license number issued by the State Contractor's Board 0031904

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584

Signed Sharel C. Fertig Sr.
By driller performing actual drilling on-site or contractor

Date 6/28/2002

USE ADDITIONAL SHEETS IF NECESSARY