WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88282
Permit No.
Basin 072

NOTICE OF INTENT NO. 51266

1. OWNER FLORIDA CANYON MINING, INC.
MAILING ADDRESS P.O. BOX 330
IMLAY, NV 89418

ADDRESS AT WELL LOCATION OFF EXIT 138
I-80 EAST NEAR IMLAY, NV

2. LOCATION SE ¼ NW ¼ Sec. 3 T 31N N/S R 33 E PERSHING County
PERMIT NO. (Issued by Water Resources) 08-580-57 (Parcel No.) WELL G (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ALLUVIUM		0	20	20
BOULDERS		20	30	10
BOULDERS & CEMENTED				
ALLUVIUM		30	150	120
ALLUVIUM & MED. FRACTURED				
ROCK		150	160	10
HARD ROCK		160	170	10
FRACTURED ROCK & CLAY		170	180	10
MED. HARD ROCK W/ CLAY		180	220	40
USED 192 50# BAGS OF 3/8 HOLE PLUG				
CEMENT 0-10 FEET				

RECEIVED
02 NOV 25 PM 12:39
STATE ENGINEERS OFFICE

Date started 10-4-02, 19
Date completed 10-11-02, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 190 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 3/4 Inches		0 Feet	220 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	PVC	SCH 40	+2	190

Perforations:
Type perforation PVC SCREEN
Size perforation .010
From 160 feet to 190 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 150
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 150 feet to 190 feet

9. WATER LEVEL
Static water level 165 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P.O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1395
Signed (By driller performing actual drilling on site or contractor)
Date 11/22/02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627