WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98287
Permit No.
Basin 072

NOTICE OF INTENT NO. 51265

1. OWNER Florida Canyon Mining, Inc.
MAILING ADDRESS P.O. Box 330
Imlay, NV 89418

ADDRESS AT WELL LOCATION Off Exit 138 I-80 East
near Imlay, Nevada

2. LOCATION ~~NE~~ SE ¼ NW ¼ Sec. 3 T 31N N/S R 33 E Pershing County
PERMIT NO. Issued by Water Resources | 08-580-57 Parcel No. | Well I Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Coarse Gravels		0	60	60
Clay & Fine to Med. Gravel		60	100	40
Silt & Fine Gravel		100	220	120
Used 108 50# bags of 3/8 hole plug				
Cement top 10 feet				

Date started October 18, 2002, 19
Date completed October 22, 2002, 19

RECEIVED 02 NOV 25 PM 12:39 STATE ENGINEERS OFFICE

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10		3

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9-3/4 Inches	0 Feet	220 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4½	PVC	Sch 40	0	200

Perforations:
Type perforation PVC Screen
Size perforation .010
From 170 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 150
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 150 feet to 200 feet

9. WATER LEVEL
Static water level 156 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hackworth Drilling, Inc. Contractor
Address P. O. Box 850 Contractor
Elko, NV 89803 Contractor

Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1395
Signed [signature] By driller performing actual drilling on site or contractor
Date 11/22/02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627