WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88295
Permit No.
Basin 089

NOTICE OF INTENT NO. 47886

1. OWNER Brett R Frey
MAILING ADDRESS 14545 Virginia Foothill Rd.
Reno, NV 89511

ADDRESS AT WELL LOCATION 4325 Jumbo Way Washoe
Valley NV. 89704

2. LOCATION SE 1/4 NE 1/4 Sec. 5 T 16 N/S R 20E E Washoe County
PERMIT NO. (Issued by Water Resources) 050-433-34 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Rock Brown		0	27	27
Rock with fractures		27	87	60
Rock with layers clay		87	107	20
DG. and brown rock		107	147	40
Hard rock Layers clay		147	267	120
Hard rock brown fractures	X	267	287	20
Hard rock granite with fractures	X	287	335	48
Washoe County water well permit # WL 020230				

RECEIVED
02 NOV 27 PM 12:13
STATE ENGINEERS OFFICE

Date started 11/22/2002 , 19__
Date completed 11/25/2002 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+		2 Hr.

8. WELL CONSTRUCTION
Depth Drilled 335 Feet Depth Cased 335 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	55	Feet
9 7/8	Inches	55	Feet	335	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	335

Perforations:
Type perforation Machine cut
Size perforation 3/32 X 3

From	275	feet to	295	feet
From	315	feet to	335	feet
From		feet to		feet
From		feet to		feet
From		feet to		feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 52'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 52 feet to 335 feet

9. WATER LEVEL
Static water level 187 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 11/25/02

USE ADDITIONAL SHEETS IF NECESSARY