


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



OFFICE USE ONLY

88297

Log No.
 Permit No.
 Basin

Ø83

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **47876**

1. OWNER **Todd Devito** ADDRESS AT WELL LOCATION **4110 Lousetown, VCH**
 MAILING ADDRESS **4110 Lousetown, VCH**
Reno, NV 89511

2. LOCATION **NW 1/4 SE 1/4 Sec. 4 T 17N** N/S R **21E E** **Storey** County
 PERMIT NO. **03-391-10** Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other **Mud**

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---|--------------|------|-----|------------|
| Black Sand-fill | | 170 | 180 | 10 |
| Black-Green rock/grey clay | | 180 | 260 | 80 |
| Fracture rock, black, green, gray clay | | 260 | 300 | 40 |
| Gravels | x | 300 | 320 | 20 |
| Black-gray frac. rock | x | 320 | 340 | 20 |
| Gray clay, mixed w/rock | | 340 | 360 | 20 |
| Gray clay | | 360 | 380 | 20 |
| Volc. rock-purple-black-gray | | 380 | 440 | 60 |
| Gray clay | | 440 | 450 | 10 |
| Volc. fractured rock-red, purple, black | x | 450 | 500 | 50 |

8. WELL CONSTRUCTION
 Depth Drilled **500** Feet Depth Cased **500** Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---------------------|-----------------|-----------------|
| 6 1/8 Inches | 170 Feet | 500 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|--------------------|-------------------------|-------------|------------|
| 5 | 10.79 | .188 | 160 | 500 |

Perforations:
 Type perforation **Factory**
 Size perforation **3/32 x 3"**

| From | feet to | feet |
|------|------------|------------|
| | 300 | 320 |
| | 380 | 400 |
| | 460 | 500 |
| | | |
| | | |

Surface Seal: Yes No
 Depth of Seal **Previous**
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level **78** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **cool** °F Quality **not tested**

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Bruce MacKay Pump & Well Service, Inc.** Contractor
 Address **1600 Mt. Rose Hwy** Contractor
Reno, NV 89511
 Nevada contractor's license number issued by the State Contractor's Board **23096**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1719**
 Signed *R. Bruce MacKay*
 By driller performing actual drilling on-site or contractor
 Date **11/7/02**

7. WELL TEST DATA

| TEST METHOD: | TEST METHOD: <input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | | |
|--------------|--|-------------------------------|--------------|
| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
| Air | 100+ | | 2 hrs |
| Pump | 15 | 8 | 2 hrs |
| | | | |
| | | | |

RECEIVED
02 NOV 27 PM 12:13
STATE ENGINEERS OFFICE

Date started **10/30/2002**, 19__
 Date completed **11/4/2002**, 19__