

OFFICE USE ONLY
 Log No. ~~88303~~ 88303
 Permit No. ~~103~~
 Basin ~~103~~

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 46299

1. OWNER Haskell Steelman ADDRESS AT WELL LOCATION 12935 BROKEN ARROW STAGE COACH, NV
 MAILING ADDRESS _____
 2. LOCATION SE 1/4 SW 1/4 Sec. 7 T. 17 N/S R. 23 E. LYON County _____
 PERMIT NO. _____ Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
DIRT-ROCK		0	60	60
SANDY BROWN CLAY		60	80	20
BLACK ROCK		80	133	53
FRACTURED BLACK ROCK		133	140	7
STICKY BROWN CLAY		140	147	7
FRACTURED B/W ROCK		147	170	23
WHITE CLAY IN GREEN ROCK		170	180	10
RUSTY WHITE CLAY GRANITE		180	185	5
DECOMPOSED GRANITE		185	200	15

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
9/16 Inches 0 Feet 125 Feet
8 3/4 Inches 125 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>14</u>	<u>.188</u>	<u>+1</u>	<u>200</u>

Perforations:
 Type perforation Factory milled
 Size perforation 3/32" X 3"
 From 180 feet to 200 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 52 ft Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 52 feet to 200 feet

Date started 22 July 02
 Date completed 24 July 02

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>257</u>		<u>1.0</u>

9. WATER LEVEL
 Static water level 150 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 67 °F Quality CLEAR

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Blain Drilling & Pump Co.
P.O. Box 1255
 Address Carson City, NV 89702
 Contractor
 Nevada contractor's license number 46498
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167
 Signed Jack Dotson
 By driller performing actual drilling on site or contractor
 Date _____

RECEIVED
 02 AUG - 9 PM 3:20
 STATE ENGINEERS OFFICE