WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88304
Permit No.
Basin 076

NOTICE OF INTENT NO. 46634

1. OWNER Betty Kiefe
MAILING ADDRESS 245 Lincoln Hwy
Wadsworth, NV 89442

ADDRESS AT WELL LOCATION 245 Lincoln Hwy.
Wadworth, Nevada 89442

2. LOCATION NW 1/4 NW 1/4 Sec. 3 T 20N N/S R 24E E Washoe County
PERMIT NO. _____ Issued by Water Resources
084-220-22 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Round River Rock		0	100	100
Sandy Clay		100	120	20
Gravel and Sand	x	120	145	25
T.D. 145		145		

Date started 10/23/2002, 19__
Date completed 10/30/2002, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30+	120	5 hours

8. WELL CONSTRUCTION
Depth Drilled 145 Feet Depth Cased 145 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11.5 Inches	0 Feet	145 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.94	.188	+1-1/2	145

Perforations:
Type perforation Factory Sawed
Size perforation 3/32 x 3
From 105 feet to 145 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 145 feet

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service
Contractor
Address P.O. Box 60130
Contractor
Reno, Nevada 89506
Nevada contractor's license number issued by the State Contractor's Board 0035387-B
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1878
Signed Larry Welch
(By driller performing actual drilling on-site or contractor)
Date 11/14/2002

USE ADDITIONAL SHEETS IF NECESSARY