


White Canyon Well

Jerry LANCASTER

11-6-02



0

100

200

300

400

500

575

F Anderson Drilling Supplies

80' Sch 80 PVC Pipe

400' # 8/3 wire

1 10320-27 Pump DC P1001i

2 Shrink's

CONNECTION From GALV To Plastic 273'

Pumping 7 Gpm @ Departure
11-08-02

CONNECTION From # 8 TO # 10 wire 400'

J Slot 5"

Liner INSTALLED From 455' To 575'

Blank Pipe 455' To 515'

Perf Pipe 515' To 575'

STATIC 463'

Pump set @ 553'

Pipe

0-273 1/2 Galv T6 Pipe

10320-27

273 To 533 1/4 Sch 80 T6 PVC Pipe

Wire

0-400' # 8/3 w GMA

TO 575'

400-575 # 10/3 w GMA

Fred Anderson & Sons Drilling, Inc
10760 Grass Valley Road
Winnemucca, Nevada. 89445
623-4203 fax 623-4225


Division of Water Resources
123 W Nye Lane Suite 246
Carson City, NV. 89706-9931

11-18-02

Attention: Tim Hunt

In Regards to your call received on Friday November 15th 2002 Intent Card # 48307. I did not deepen the well I only lowered the pump in an existing well. The static in this well was 463' Pump was set at 470' I was there to deepen the well but it was determined that the well was already 575' deep with no casing in it. I installed a 5" casing Liner from 460' to 575' which is the bottom of the well. I then lowered the pump to 553' I believe that maybe I was given the wrong permit #. I am sure this is just an error in reporting. This is and old pumping site from the looks of the surrounding material that has been in place at one time, corrals, cement watering trough, this has an odd size casing 6" it may even be a prethirties well. I am faxing the work I preformed as requested by Rob Martinez. If there is anything else that I can do to help let me know.

Thanks Fred Anderson

A handwritten signature in black ink, appearing to read 'Fred Anderson', with a long horizontal flourish extending to the right.