COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88317
Permit No.
Basin 103

NOTICE OF INTENT NO. 46412

1. OWNER PHIL CLARK
MAILING ADDRESS 240 SUTRO RD
DAYTON, NV 89403

ADDRESS AT WELL LOCATION 355 OPHIR RD
DAYTON, NV 89403

2. LOCATION NE ¼ SE ¼ Sec 4 T 16 N R 22 E LYON County
PERMIT NO. (Issued by Water Resources) 19/133/02 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BLOW SANDS		0	3	3
HARDPAN SANDS		3	6	3
BLOW SANDS		6	21	15
COURSE SANDS DG		21	87	66
BROWN CLAY		87	146	59
GRAY CLAY		146	167	21
FRACTURED SANDS	XXX	167	190	23

RECEIVED 02 JUL 30 AM 9:16 STATE ENGINEER'S OFFICE

Date started 7/11, 20 02
Date completed 7/12, 20 02

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+	25	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 190 ~~200~~ Feet Depth Cased 190 ~~200~~ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 Inches	0 Feet	190 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	190

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 170 feet to 190 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☒ Poured
Gravel Packed: ☒ Yes ☐ No
From 55 feet to 190 feet

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow G.P.M ~~257~~ P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 88706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Greene
By driller performing actual drilling on site or contractor
Date 7/14/02

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429