

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 88355
 Permit No. 40013
 Basin 15B

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50589

1. OWNER Linford Miller ADDRESS AT WELL LOCATION Diamond Valley, Eureka,
 MAILING ADDRESS HC62 Box 62155 NV 89316
Eureka, NV 89316

2. LOCATION SE 1/4 NE 1/4 Sec. 32 T 211/2N N/S R 54E E Eureka County
 PERMIT NO. 67658 T 40013 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other

4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock

5. WELL TYPE Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	24	24
Gray Silt		24	30	6
Black Gray Clay		30	45	15
gray Silty Clay		45	52	7
Black Clay		52	58	6
Brown Silt		58	62	4
Fine Gray Sand		62	67	5
Gray Clay		67	70	3
Brown Clay		70	83	13
Tan Clay		83	90	7
Brown Clay		90	107	17
Gray Sand Stone		107	115	8
Fine Gray Sand		115	135	20
Gray Clay		135	138	3
Gravel		138	143	5
Gray Clay		143	156	13
Fine Sand		156	171	15
Black Clay		171	185	14
Gray Clay		185	208	23
Fine Gray Sand		208	210	2
Fine Brown sand		210	221	11
Brown Clay		221	240	19
Gray Clay		240	244	4
White Clay		244	250	6
Brown Clay		250	258	8
Gravel		258	261	3
Brown Clay		261	263	2
Brown Sand Stone		263	272	9
Gravel	X	272	279	7
Brown Clay		279	288	9
Brown Sand Stone		288	293	5
Cemented Gravel	XX	293	300	7
Brown Sand Stone	XX	300	302	2

Continued on next page

8. WELL CONSTRUCTION
 Depth Drilled 580 Feet Depth Cased 580 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 50 Feet
36 Inches 26 Inches
 From 50 Feet To 580 Feet
26 Inches 580 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	42	.250	+1	580
30	20.75	.65	0	30

Perforations:
 Type perforation Mill Cut
 Size perforation 3/16

From 280 feet to 580 feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 50
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 580 feet

9. WATER LEVEL
 Static water level 90 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality unknown

Date started 07/27/2002, 19
 Date completed 08/07/2002, 19

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer			
<input type="checkbox"/> Pump			
<input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. Contractor
 Address P.O. Box 1265 Contractor
Fallon Nv. 89407-1265
 Nevada contractor's license number issued by the State Contractor's Board 29064
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed Wayne Parsons
 By driller performing actual drilling on-site or contractor
 Date 09/18/2002