

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

office use only
Log No. 28360
Permit No.
Basin 092-B
NOTICE OF INTENT NO 61344

1. OWNER Ed Griffith
MAILING ADDRESS 9430 Arrowhead Way
Reno NV 89506

ADDRESS AT WELL LOCATION 9370 Bull Road
Washoe County

2. Location SE 1/4 NE 1/4 Sec 11 T 20N R 19E
PERMIT NO. PARCEL NO. 552-040-42 SUBDIVISION NAME

3. WORK PERFORMED			4. PROPOSED USE			5. WELL TYPE		
<input checked="" type="checkbox"/> New Well	Replace	Recondition	<input checked="" type="checkbox"/> Domestic	Irrigation	Test	Cable	<input checked="" type="checkbox"/> Rotary	RVC
Deepen	Abandon	Other	Municipal/Industrial	Monitor	Stock	Air	Other	<input checked="" type="checkbox"/> Mud

6. LITHOLOGIC LOG					8. WELL CONSTRUCTION				
Material	Water Strata	From	To	Thickness	Depth Drilled	HOLE DIAMETER (BIT SIZE)		Depth Cased	
						From	To		
DG		0	185	185	10 5/8 inches	0 feet	248 feet		
Fractured granite.		185	223	38	inches	feet	feet		
Hard granite.		223	228	5	inches	feet	feet		
Fractured granite.		228	235	7	CASING SCHEDULE				
Hard granite.		235	248	13	Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
					6 5/8	12.94	188	+1 1/2	248
					Perforations::				
					Type Perforation	Factory			
					Size perforation	3/32 x 3"			
					From	188 feet	to 248 feet		
					From	feet	to feet		
					From	feet	to feet		
					From	feet	to feet		
					From	feet	to feet		
					From	feet	to feet		
					Surface Seal	<input checked="" type="checkbox"/> YES	No	Seal Type:	
					Depth of Seal	50 feet		Neat Cement	
								<input checked="" type="checkbox"/> Cement Grout	
								<input checked="" type="checkbox"/> Concrete Grout	
					Gravel Packed:	<input checked="" type="checkbox"/> Yes	<input checked="" type="checkbox"/> No		
					From	50 feet	to 248 feet		
					9 WATER LEVEL				
					Static water level	140 feet	below land surface		
					Artesian flow	0 GPM	0 P.S.I.		
					Water Temperature	cold	Degrees F	Quality	

Date started 8-18 -02
Date completed 8-23 -02

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	x	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (hours)		
12	20			
20	40			
30	100	3		

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name McKay Drilling, Inc.
2290 Pioneer Drive
Reno, NV 89509

NV Contractors No. 14170
NV Driller's Lic (on site) 2121

Signed

By driller performing actual drilling on site or contractor

Date 8-27 -02

RECEIVED
02 AUG 28 AM 10:54
STATE ENGINEERS OFFICE

