STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

office use only
Log No. 88377
Permit No. 26154
Basin 092-B

NOTICE OF INTENT NO. 48476

1. OWNER: Space Era Mobile Home Park
MAILING ADDRESS: 145 West Surge
Lemon Vally NV
LADDRESS AT WELL LOCATION: 145 West Surge

2. Location: SW 1/4 SW 1/4 Sec 34 T 21 N R 19E Washoe County
PERMIT NO. 26154 PARCEL NO. 080-191-07 SUBDIVISION NAME

3. WORK PERFORMED: New Well; X Replace; Recondition; Deepen; Abandon; Other

4. PROPOSED USE: Domestic; X Municipal/Industrial; Irrigation; Monitor; Test; Stock

5. WELL TYPE: Cable; X Rotary; RVC; Air; Other; X Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & sand.		0	63	63
				0
DG		63	98	35
				0
Clay.		98	123	25
				0
Granite.		123	215	92
				0
Clay.		215	222	7
				0
Granite.		222	230	8
				0
Well not completed do to				0
stop work order from				0
Washoe County Health				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0

Date started 12-17 -02
Date completed 1-2 -03

7. WELL TEST DATA
TEST METHOD: Bailer Pump x Air Lift

G.P.M	Draw Down (Feet Below Static)	Time (hours)

8. WELL CONSTRUCTION
Depth Drilled 330 feet Depth Cased 224 feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4	inches	0 feet	224 feet
7 7/8	inches	224 feet	330 feet
	inches	feet	feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	188	+3	224

Perforations::
Type Perforation Factory
Size perforation 3/32 x 3"
From 60 feet to 100 feet screen
From 120 feet to 180
From feet to feet
From feet to feet
From feet to feet

Surface Seal X YES No Seal Type:
Depth of Seal 50 feet Neat Cement
x Pumped Cement Grout
Poured x Concrete Grout
Gravel Packed: x Yes No
From 50 feet to 224 feet

9. WATER LEVEL
Static water leve50 feet below land surface
Artesian flow 0 GPM 0 P.S.I.
Water Temperature cold Degrees F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name McKay Drilling, Inc.
2290 Pioneer Drive
Reno, NV 89509
NV Contractors No. 14170
NV Driller's Lic (on site) 2121
Signed
By driller performing actual drilling on site or contractor
Date 1-28 -03

88377

STOPWORK ORDER

WASHOE COUNTY
DISTRICT HEALTH DEPARTMENT
1001 E. NINTH STREET
RENO, NV 89512
PHONE: 328-2434

DATE: 12-3-04 TIME: [illegible] PERMIT # [illegible]

PROPERTY OWNER: [illegible]

DRILLING COMPANY: [illegible]

DRILLING SITE: [illegible]

VIOLATION SECTION

- [ ] 020.015 - DRILLING COMPANY DOES NOT HAVE VALID STATE CONTRACTORS LICENSE AND/OR LOCAL BUSINESS LICENSE.
- [ ] 020.020 - NO DISTRICT HEALTH WELL CONSTRUCTION PERMIT ON FILE.
- [ ] 020.045 - UNAPPROVED CHANGE OR DEVIATION FROM APPROVED PLOT PLAN.
- [ ] 030.035 - NO LICENSED DRILLER ON DRILL SITE.
- [x] _____ - OTHER [illegible]
- [ ] _____ - OTHER [illegible]
- [ ] _____ - OTHER _____

YOU HAVE BEEN NOTIFIED OF THIS VIOLATION(S) AND ARE HEREBY ORDERED TO CEASE CONSTRUCTION, INSTALLATION OR ALTERATION OF THIS WELL PER SECTION 130.055 WCDHD REGS. GOVERNING WELL CONSTRUCTION.

FAILURE TO COMPLY WITH THIS ORDER MAY RESULT IN A FINE OF UP TO $1,000.00 AND/OR 6 MONTHS IN JAIL FOR EACH VIOLATION. REAPPROVAL BY THE HEALTH AUTHORITY IS REQUIRED BEFORE THIS STOPWORK ORDER CAN BE RECINDED BY THE HEALTH REPRESENTATIVE SIGNED BELOW.

By [illegible]

UNLAWFUL TO REMOVE THIS TAG
Per Well Reg. Section # 030.055

HEALTH DEPT. - WHITE COPY, ISSURER - YELLOW COPY, VIOLATOR - BUFF
H-713-122