WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

**PRINT OR TYPE ONLY**
**DO NOT WRITE ON BACK**

# STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88395
Permit No.
Basin Ø92-A

NOTICE OF INTENT NO. 47873

**1.** OWNER Bonnie Robertson
MAILING ADDRESS 10895 Abiliene Rd.
Reno, NV 89506

ADDRESS AT WELL LOCATION 10895 Abiliene Rd.

**2.** LOCATION NE 1/4 SW 1/4 Sec. 24 T 21N N/S R 18E E Washoe County
PERMIT NO. (Issued by Water Resources) 086-203-14 (Parcel No.) Subdivision Name

**3. WORK PERFORMED**
[ ] New Well [ ] Replace [ ] Recondition
[X] Deepen [ ] Abandon [ ] Other

**4. PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

**5. WELL TYPE**
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

**6. LITHOLOGIC LOG**

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Black/gray sand | x | 240 | 260 | 20 |
| Gray sand | x | 260 | 320 | 60 |

Washoe Co. Permit #WL020224

RECEIVED 02 NOV 27 PM 12:13 STATE ENGINEERS OFFICE

Date started 11/13/2002, 19__
Date completed 11/14/2002, 19__

**7. WELL TEST DATA**

TEST METHOD: [ ] Bailer [X] Pump [X] Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| Air | 20+ | | 2 hrs |
| Pump | 15 | 10 | 1 hr |

**8. WELL CONSTRUCTION**
Depth Drilled 320 Feet Depth Cased 320 Feet

**HOLE DIAMETER (BIT SIZE)**

| | | From | | To | |
|---|---|---|---|---|---|
| 6 1/8 | Inches | 240 | Feet | 320 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

**CASING SCHEDULE**

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 5 | 10.79 | .188 | 220 | 320 |

**Perforations:**
Type perforation Factory
Size perforation 3/32" x 3"
From 300 feet to 320 feet
From 240 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

**9. WATER LEVEL**
Static water level 95 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality not tested

**10. DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 11/14/02

USE ADDITIONAL SHEETS IF NECESSARY