

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 88419
 Permit No. _____
 Basin 061

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50820

1. OWNER Barrick Goldstrike Mines PZ02-3 ADDRESS AT WELL LOCATION Barrick Goldstrike minesite, north of Carlin, NV.
 MAILING ADDRESS P.O. Box 29
Elko, NV 89803

2. LOCATION NE 1/4 SE 1/4 Sec. 23 T 36N N/S R 49E E Eureka County
 PERMIT NO. N/A Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Carlin (gravels & clay)</u>		<u>0</u>	<u>585</u>	<u>585</u>
<u>Bedrock</u>		<u>585</u>	<u>620</u>	<u>35</u>
Construction Detail:				
<u>Cement</u>		<u>0</u>	<u>20</u>	<u>20</u>
<u>Hole plug</u>		<u>20</u>	<u>139.5</u>	<u>119.5</u>
<u>Gravel</u>		<u>139.5</u>	<u>164.8</u>	<u>25.3</u>
<u>Hole plug</u>		<u>164.8</u>	<u>260</u>	<u>95.2</u>
<u>Gravel</u>		<u>260</u>	<u>310.5</u>	<u>50.5</u>
<u>Hole plug</u>		<u>310.5</u>	<u>370.3</u>	<u>59.8</u>
<u>Gravel</u>		<u>370.3</u>	<u>420</u>	<u>49.7</u>
<u>plug</u>		<u>420</u>	<u>490.5</u>	<u>70.5</u>
<u>Gravel</u>		<u>490.5</u>	<u>542</u>	<u>51.5</u>
<u>Hole plug</u>		<u>542</u>	<u>561</u>	<u>19</u>
<u>Gravel</u>		<u>561</u>	<u>588</u>	<u>27</u>
<u>Hole plug</u>		<u>588</u>	<u>612</u>	<u>24</u>
<u>Fill</u>		<u>612</u>	<u>620</u>	<u>8</u>

8. WELL CONSTRUCTION

Depth Drilled 620 Feet Depth Cased 585 Feet

HOLE DIAMETER (BIT SIZE)

From		To	
<u>17.50</u> Inches	<u>0</u> Feet	<u>20</u> Feet	<u>20</u> Feet
<u>7.875</u> Inches	<u>20</u> Feet	<u>620</u> Feet	<u>620</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>13.375</u>	<u>68.75</u>	<u>0.500</u>	<u>+2</u>	<u>20</u>
<u>1: 2.375</u>	<u>3.65</u>	<u>0.154</u>	<u>+1</u>	<u>585</u>
<u>2: 2.375</u>	<u>3.65</u>	<u>0.154</u>	<u>+1</u>	<u>535</u>

Perforations:
 Type perforation Slot
 Size perforation 0.125"

From	To	feet to	feet
<u>1: 565</u>	<u>585</u>		<u>585</u>
<u>2: 495</u>	<u>535</u>		<u>535</u>

Surface Seal: Yes No Seal Type:
 Depth of Seal 20' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From See Detail feet to _____ feet

9. WATER LEVEL
 Static water level 1: 567.2 2: 360 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature Cool °F Quality Fair

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2144
 Signed Paul Stoddard
 By driller performing actual drilling on-site or contractor
 Date 10/9/02

Date started 9/30/2002, 19
 Date completed 10/7/2002, 19

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>1</u>	<u>Trace</u>	<u>Not Meas.</u>	<u>4</u>
<u>2</u>	<u>2 - 4</u>	<u>Not Meas.</u>	<u>4</u>

B.S.T.C