

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 88415
 Permit No. _____
 Basin Plata
 NOTICE OF INTENT NO. 56820

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Barrick Goldstrike Mines PZ02-3
 MAILING ADDRESS P.O. Box 29
Elko, NV 89803

ADDRESS AT WELL LOCATION Barrick Goldstrike
minesite, north of Carlin, NV.

2. LOCATION NE 1/4 SE 1/4 Sec. 23 T 36N N/S R 49E E Eureka County
 PERMIT NO. N/A Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Carlin (gravels & clay)		0	585	585
Bedrock		585	620	35
Construction Detail:				
Cement		0	20	20
Hole plug		20	139.5	119.5
Gravel		139.5	164.8	25.3
Hole plug		164.8	260	95.2
Gravel		260	310.5	50.5
Hole plug		310.5	370.3	59.8
Gravel		370.3	420	49.7
plug		420	490.5	70.5
Gravel		490.5	542	51.5
Hole plug		542	561	19
Gravel		561	588	27
Hole plug		588	612	24
Fill		612	620	8

8. WELL CONSTRUCTION
 Depth Drilled 620 Feet Depth Cased 585 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
17.50 Inches 0 Feet 20 Feet
7.875 Inches 20 Feet 620 Feet
 inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
13.375	68.75	0.500	+2	20
1: 2.375	3.65	0.154	+1	585
2: 2.375	3.65	0.154	+1	535

Perforations:
 Type perforation Slot
 Size perforation 0.125"
 From 1: 565 feet to 585 feet
 From 2: 495 feet to 535 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 20' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From See Detail feet to _____ feet

9. WATER LEVEL
 Static water level 1: 567.2 2: 360 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature Cool °F Quality Fair

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2144
 Signed Paul Stoddard
 By driller performing actual drilling on-site or contractor
 Date 10/9/02

Date started 9/30/2002 19
 Date completed 10/7/2002 19

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
1	<u>Trace</u>	<u>Not Meas.</u>	<u>4</u>
2	<u>2 - 4</u>	<u>Not Meas.</u>	<u>4</u>

BST.L