WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88497
Permit No.
Basin 102

NOTICE OF INTENT NO. 46296

1. OWNER Guffy
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1685 GREEN ST. SILVER SPRINGS, NV

2. LOCATION NW ¼ SE ¼ Sec. 6 T. 17 N/S R. 25 E. LYON County
PERMIT NO. Issued by Water Resources
17-084-01 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	6	6
ROCK - SAND		6	42	36
SANDY BROWN CLAY		36	55	19
ROCK - SAND	X	55	125	70
GRAY SANDY CLAY		125	132	7
SANDY FINE GRAVEL	X	132	157	25
BROWN CLAY-GRAVEL	X	157	167	10
MEDIUM GRAVEL	X	167	174	7
BROWN SANDY CLAY		174	180	6

BOTTOM OF HOLE FILLED W/GRAVEL TO TAKE WATER FROM 155 FT TO 165 FT.

RECEIVED 03 JUL 23 PM 12:31 STATE ENGINEER'S OFFICE

Date started 18 July 03, 19
Date completed 19 July 03, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+		1.0

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 165 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10 5/8	0	180

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	14	.188	+1	165

Perforations:
Type perforation Factory milled
Size perforation 3/32" x 3"
From 155 feet to 165 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 FT
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 165 feet

9. WATER LEVEL
Static water level 44 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality CLEAR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Blain Drilling & Pump Co.
Address P.O. Box 1255 Carson City, NV 89702
Contractor

Nevada contractor's license number issued by the State Contractor's Board 46498
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167
Signed Jack Dotson
By driller performing actual drilling on site or contractor
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627