WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88514
Permit No.
Basin 064

NOTICE OF INTENT NO. 46633

1. OWNER Western States Minerals
MAILING ADDRESS 250 S. Rock Blvd.
Reno, NV 89502

ADDRESS AT WELL LOCATION Well # 2

2. LOCATION SE 1/4 SE 1/4 Sec. 4 T 33N N/S R 44E E Humbolt County
PERMIT NO. WSM001 Issued by Water Resources
7-471-02 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other Drv Pnt

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Silty Clay | | 0 | 12 | 12 |
| Fine Gravel & Sand | | 12 | 15 | 3 |
| T.D. 15 feet | | 15 | | |

Date started 10/04/2002 , 19__
Date completed 10/04/2002 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 15 Feet Depth Cased 15 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 6 | Inches | 0 | Feet | 6 | Feet |
| 2.25 | Inches | 6 | Feet | 15 | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 3/4 | .278 | S-80 | 0 | 15 |

Perforations:
Type perforation Factory Slot
Size perforation .010
From 6 feet to 15 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal [X] Yes [ ] No
Depth of Seal 5 feet
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 6 feet to 15 feet

9. WATER LEVEL
Static water level 12.8 feet below land surface
Artesian flow G.P.M. P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service Contractor
Address P.O. Box 60130 Contractor
Reno,Nevada 89506
Nevada contractor's license number issued by the State Contractor's Board 35387-B
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066
Signed [signature] By driller performing actual drilling on-site or contractor
Date 10/15/2002

USE ADDITIONAL SHEETS IF NECESSARY