WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88526
Permit No.
Basin 071

NOTICE OF INTENT NO. 74284

1. OWNER McCOMBS FAMILY TRUST
MAILING ADDRESS 3000 VAN DIEST RD WINNEMUCCA, NV 89445
ADDRESS AT WELL LOCATION VAN DIEST RD

2. LOCATION NE ¼ NW ¼ Sec. 36 T. 34 N/S R. 37 E. PERSHING County
PERMIT NO. 68955 [redacted] Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other REVERSE

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	10	10
SAND, SM GRAVEL		10	23	13
BROWN CLAY		23	44	21
SAND, SM GRAVEL		44	59	15
BR CLAY W/SAND STREAKS		59	85	26
COARSE SAND		85	93	8
BR. CLAY		93	147	54
SAND, GRAVEL		147	153	6
BR. CLAY		153	159	6
SAND, GRAVEL		159	162	3
BR. CLAY		162	167	5
BR CLAY W/SM GRAVEL		167	178	11
BR CLAY		178	207	29
MED-COARSE SAND, GRAVEL		207	214	7
BR CLAY		214	222	8
MED-COARSE SAND, GRAVEL		222	225	3
BR CLAY		225	228	3
MED-COARSE SAND		228	231	3
BR CLAY		231	250	19
SAND, GRAVEL		250	258	8
BR CLAY		258	288	30
SAND, GRAVEL		288	296	8
BR CLAY		296	312	16
SAND, GRAVEL		312	319	7
BR CLAY W/SM SAND STREAKS		319	360	41
SAND, GRAVEL		360	363	3
BR CLAY		363	365	2
SAND, GRAVEL		365	388	23
BR CLAY, W/SOME SAND STREAKS		388	443	55

Date started MAY 7, 2002
Date completed May 17, 2002

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
No test		

8. WELL CONSTRUCTION
Depth Drilled 443 Feet Depth Cased 443 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
24 Inches	0 Feet	443 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16"		.375	+2	443
EXCEPT WHERE WIRE WRAP SCREENS ARE LOCATED LISTED BELOW				

Perforations:
Type perforation 16" JOHNSON WIRE WRAP SCREENS
Size perforation SLOT SIZE .035
From 174 feet to 194 feet
From 254 feet to 274 feet
From 354 feet to 394 feet
From 418 feet to 438 feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 52'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 52 feet to 443 feet

9. WATER LEVEL
Static water level 53 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RIVERSIDE INC. Contractor
Address PO BOX 720 Contractor
PARMA, ID 83660
Nevada contractor's license number issued by the State Contractor's Board 0044881
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1919
Signed [signature] By driller performing actual drilling on site or contractor
Date 5-22-02

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627