

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49343

1. OWNER Roy Planota ADDRESS AT WELL LOCATION 2821 WADE ST  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION S 1/4 SE 1/4 Sec. 27 T. 14 N/S R. 20 E Douglas County  
 PERMIT NO. 420-27-810-021 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	16	16
SANDY BROWN CLAY		16	28	12
SANDY BR CLAY-GRAVEL	X	28	90	62
BROWN SANDY CLAY		90	105	15
FINE GRAVEL-SAND		105	142	37
MEDIUM GRAVEL-SAND		142	162	20
COARSE GRAVEL	X	162	200	38

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 Feet To 200 Feet  
9 7/8 Inches  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>14</u>	<u>1.158</u>	<u>+1</u>	<u>200</u>

Perforations:  
 Type perforation Factory milled  
 Size perforation 3/32" x 3"  
 From 190 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 53 ft  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 53 feet to 200 feet

9. WATER LEVEL  
 Static water level 36 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD Quality CLEAR

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Blain Drilling & Pump Co.  
P.O. Box 1255  
 Address Carson City, NV 89702  
 Contractor

Date started 26 Sep 02, 20\_\_\_\_  
 Date completed 27 Sep 02, 20\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25+</u>		<u>1.0</u>

Nevada contractor's license number issued by the State Contractor's Board 46498  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167  
 Signed Jack Dotson  
 By driller performing actual drilling on site or contractor  
 Date \_\_\_\_\_