

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49423

1. OWNER NEVADA DEPT OF AGRICULTURE ADDRESS AT WELL LOCATION GARDNERVILLE
 MAILING ADDRESS 350 CAPITAL HILL AVENUE ELEMENTARY SCHOOL, TOLAN STREET,
RENO NV 89502 GARDNERVILLE NV
 2. LOCATION SE 1/4 SW 1/4 Sec. 33 T. 13 N 20 E Douglas County
 PERMIT NO. MO-1261 1320 33 402 059 Subdivision Name _____
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
MEDIUM BROWN SILT + CLAY FORMING 1" BALLS		0	3	
1" - 2" ROUNDED RIVER DEPOSITS + SAND		3	5	
2-5" RIVER DEPOSITS + FINE GRAINED SAND	X	5	9.7	

8. WELL CONSTRUCTION
 Depth Drilled 9.7 Feet Depth Cased 9.7 Feet
 HOLE DIAMETER (BIT SIZE)
 From 6.625 Inches To 9.7 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		SCHED 40	0	9.7

Perforations:
 Type perforation MACHINED SLOT
 Size perforation .01"
 From 9.2 feet to 4.2 feet
 _____ feet to _____ feet
 _____ feet to _____ feet
 _____ feet to _____ feet

According to Assessor's records, parcel is owned by Douglas Co. School Dist.

Surface Seal: Yes No
 Depth of Seal 3.5
 Cement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Well Packed: Yes No
 From 9.7 feet to 3.5 feet

Date started 09/16/02
 Date completed 09/16/02

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>0.5</u>		<u>0.75</u>

9. WATER LEVEL
 Static water level 8.9 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name U.S.G.S. Contractor
 Address 333 W. Nye Ln Contractor
CARSON CITY 89706
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller FR-2178
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 10/28/02