WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88532
Permit No.
Basin 105

NOTICE OF INTENT NO. 49425

1. OWNER Nevada Dept of Agriculture
MAILING ADDRESS 350 Capital Hill Ave. Reno Nv 89502
ADDRESS AT WELL LOCATION Minden Elementary School, Baler Street Minden Nv

2. LOCATION SE ¼ NE ¼ Sec. 29 T. 13 (N)/S R. 20 (E) Douglas County
PERMIT NO. MO-1261 (Issued by Water Resources) | 1320 29 000 002 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Dark Brown Clay + Gravel | X | 0 | 9 | 9 |
| Gravel with some clay | X | 9 | 12 | 3 |
| Gravel, cobbles, some clay | X | 12 | 17.7 | 5.7 |

Date started 09/30, 2002
Date completed 09/30, 2002

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 2+ | | 1.0 |

8. WELL CONSTRUCTION
Depth Drilled 17.7 Feet Depth Cased 17.7 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 6.625 Inches | | 0 Feet | 17.7 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2" | | Sched 40 | 0 | 17.7 |

Perforations:
Type perforation MACHINED SLOT
Size perforation .01
From 17.2 feet to 12.2 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 7.5'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 7.5 feet to 17.7 feet

9. WATER LEVEL
Static water level 3.40 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name U.S.G.S.
Contractor
Address 333 W. Nye Lane
Contractor
Carson City NV 89706
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller FP-2178
Signed
By driller performing actual drilling on site or contractor
Date 10/28/02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627