WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83541
Permit No.
Basin 105

NOTICE OF INTENT NO. 46766

1. OWNER Syncon Homes
MAILING ADDRESS 2221 Meridian Blvd. #A Minden, NV. 89423
ADDRESS AT WELL LOCATION North Termination of Longdrive

2. LOCATION NE ¼ NE ¼ Sec. 8 T. 14 N/S R. 20 E Douglass County
PERMIT NO. M/a-1265 (Issued by Water Resources) 1420-08-215-001 (Parcel No.) Sunridge III (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty sand		0	16½	16½
Sand with silt		16½	19½	3
Sand with Clay		19½	22½	3
Clayey sand		22½	24½	2
Silty sand		24½	26	1½
Sand		26	28	2
Clayey sand		28	30	2
Silt, Clayey Sand	31'	30	34	4
Sand		34	35	1

Hole #B7

Date started 9-25-02, 19
Date completed 9-25-02, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	N/A	

8. WELL CONSTRUCTION
Depth Drilled 35 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	35 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		SCH 40 PVC	0	25

Perforations:
Type perforation Factory Slot
Size perforation .020
From 25 feet to 35 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 5' Bentonite
Placement Method: ☐ Pumped ☒ Poured 20'-25' Bentonite
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout Bentonite

Gravel Packed: ☒ Yes ☐ No
From 25 feet to 35 feet

9. WATER LEVEL
Static water level 31 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature <85 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Haz-Tech Drilling (Contractor)
Address PO Box 940 (Contractor)
Meridian, Id. 83680
Nevada contractor's license number issued by the State Contractor's Board 0038018
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1803-T1
Signed Jon Adams (By driller performing actual drilling on site or contractor)
Date 10-15-02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627