WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 58545
Permit No.
Basin 105

NOTICE OF INTENT NO. 46766

1. OWNER Syncon Homes
MAILING ADDRESS 2221 Meridian BLVD. #A Minden, NV. 89423
ADDRESS AT WELL LOCATION North Termination of Longdrive

2. LOCATION NE ¼ NE ¼ Sec. 8 T. 14 N/S R. 20 E/W Douglass County
PERMIT NO. M/O-1245 Issued by Water Resources
1420-08-215-001 Parcel No.
Sunridge III Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty sand		0'	17'	17'
Poorly graded sand with silt	19'	17'	19'	2'
Clayey sand		19'	23'	4'
Poorly graded sand with clay		23'	29'	6'

Hole # B3

Seal Depth
0'-5'
13'-18'

Date started 9-24-02, 19
Date completed 9-24-02, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled 29 Feet Depth Cased 29 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	29 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		sch 40 PVC	0	19

Perforations:
Type perforation Factory slot
Size perforation .020
From 19 feet to 29 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 5/13'-18' Bentonite
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout ☒ Bentonite chips
Gravel Packed: ☒ Yes ☐ No
From 18' feet to 29' feet

9. WATER LEVEL
Static water level 19' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature <85 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Haz-Tech Drilling (Contractor)
Address P.O. Box 940 Meridian, Id. 83680 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0038018
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1803-T1
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 10-15-02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627