

OFFICE USE ONLY
 Log No. 83546
 Permit No. ~~68196~~
 Basin. 064

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. _____

1. OWNER Russell Parker ADDRESS AT WELL LOCATION N40.806362 W116.959660 NAD83
 MAILING ADDRESS P.O. Box 129
Valmy, NV 89438
 2. LOCATION Sec 24 T 34 R 44 E Lander County
 PERMIT NO. 707179-T/68486 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	6	
Light to coarse Bk Sand		6	9	
Brown Clay		9	12	
Light to coarse Bk Sand		12	15	
Brown Clay		15	43	
Med. coarse Bk Sand		43	46	
Brown Sandstone		46	49	
Green Clay		49	60	
Blue Clay & Sandstone		60	159	
Green Clay		159	165	
Brown Sandy Clay		165	175	
Brown Med Sand w/ gravel		175	180	
Light Brown Sand & Clay		180	233	
Brown Clay w/ gravel		233	271	
Coarse Sand w/ clay		271	275	
Brown Clay & Sand		275	375	

24" CASING .375" x 100'
 to 100' = Seal in
 with Cement Grout

8. WELL CONSTRUCTION
 Depth Drilled 375 Feet Depth Cased 325 Feet
 HOLE DIAMETER (BIT SIZE)
 From 3.2 Inches To 100 Feet
2.4 Inches 100 Feet 375 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
110"		.375	72	160
110"		.375	180	200
110"		.375	210	225
160"		.375	235	275

Perforations:
 Type perforation WIRE WRAP
 Size perforation .030
 From 160 feet to 180 feet
 From 200 feet to 210 feet
 From 225 feet to 235 feet
 From 275 feet to 375 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50' feet to 375' feet

9. WATER LEVEL
 Static water level 65' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Riverside Inc Contractor
 Address P.O. Box 720 Contractor
Parma Id.
 Nevada contractor's license number 004980
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1919
 Signed Jim Paul Ad' Dash
 by driller performing actual drilling on site or contractor
 Date 4-4-02

Date started 3-5-01
 Date completed 3-29-02

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>1326</u>	<u>222'</u>	<u>2hrs</u>