

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 88554
 Permit No. 102
 Basin 102

NOTICE OF INTENT NO. 47415

1. OWNER Rodie Forster (Granite) ADDRESS AT WELL LOCATION 2685 Almond
 MAILING ADDRESS Silver Springs NV
 2. LOCATION N 1/4 NE 1/4 Sec. 17 T. 18 N/S R. 25 E. Lyon Co County
 PERMIT NO. 06724 Parcel No. 15-262-13 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>(old) 7/7/01</u>				
<u>We set test pump in well to clean well out, and clean water, after pumping well for one 1/2 hours water temp was 185 degrees, the PVC casing collapsed.</u>				
<u>We reset drill up and pulled out 80 feet of casing and drilled out the rest to 140 feet.</u>				
<u>We then installed 6" steel casing to 120 feet.</u>				
<u>We forgot to reduce log for well, until customer called, and wanted copy of new log.</u>				

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 121 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 140 Feet
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>		<u>1/8</u>	<u>1</u>	<u>120</u>

Perforations:
 Type perforation Sawed
 Size perforation 1/8 x 3" 6 Rows
 From _____ feet to _____ feet
 From 120 feet to 120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 13 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 185 °F Quality CLEAR

Date started 7/26/01, 20____
 Date completed 7/27/01, 20____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40</u>	<u>30'</u>	<u>1 1/2 hrs.</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Seach Drilling Inc. Contractor
 Address PO Box 599 Contractor
Silver Springs NV 89429

Nevada contractor's license number issued by the State Contractor's Board 31841

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
1740

Signed Arthur L. Seach
 By driller performing actual drilling on site or contractor

Date 3/26/05

