

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 88564
 Permit No. _____
 Basin. Ø35

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 50418

1. OWNER CHARLES & DOROTHY WILTSIE ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 615 Onyo Way
Sparks, Nevada 89436
 2. LOCATION NE 1/4 NE 1/4 Sec 19 T 21n N/S R 21 E Washoe County
 PERMIT NO. 076-690-65 Spanish Springs
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Weathered granite		0	46	46
Rusty weathered granite		46	47	1
Weathered granite		47	61	14
Gray granite, some weathered streaks		61	240	179
Weathered granite with clay streaks		240	246	6
Gray granite		246	360	114
Clay		360	361	1
Gray granite		361	380	19
Soft zone (app 2 GPM)	X	380	381	1
Weathered granite with clay streaks		381	451	70
Gray granite		451	472	21
Fracture	X	472	473	1
Gray granite		473	507	34
Weathered granite		507	574	67
Fracture	X	574	575	1
Gray granite, some weathered, hard		575	630	55
Fracture	X	630	636	6
Gray granite		636	642	6

8. WELL CONSTRUCTION
 Depth Drilled 642 Feet Depth Cased 642 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 642 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	642

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 451 feet to 477 feet
 From 557 feet to 597 feet
 From 617 feet to 637 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 642 feet

9. WATER LEVEL
 Static water level 290 feet below land surface
 Artesian flow _____ G.P.M. 22 P.S.I.
 Water temperature cold °F Quality clear

Date started October 7, 2002, 20 _____
 Date completed October 15, 2002, 20 _____

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
22		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC.
 Address P.O. BOX 12370
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date October 17, 2002