WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88583
Permit No.
Basin 047

NOTICE OF INTENT NO. 47625

1. OWNER Canyon Construction Co.
MAILING ADDRESS P. O. Box 2030
Elko, NV 89803

ADDRESS AT WELL LOCATION Ranch near
Harrison Pass Road

2. LOCATION NW ¼ SW ¼ Sec. 1 T. 28 N/S R. 56 E. Elko County
PERMIT NO. 63472 (Issued by Water Resources) 006-025-006 (Parcel No.) Tract of Land (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [X] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Clay and Gravel		2	165	163
Hard Rock		165	185	20
Soft Clay		185	191	6
Hard Rock		191	198	7
Gravel and Clay	X	198	235	37
Hard Rock	X	235	237	2
Soft Gravel and Clay	X	237	251	14
Cemented Sand & Gravel	X	251	305	54
Clay and Gravel	X	305	414	109
Hard Rock & Gravel	X	414	445	31
Clay and Gravel		445	520	75

Date started April 15, 2002, 19
Date completed May 6, 2002, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
200+		4 hrs.

8. WELL CONSTRUCTION
Depth Drilled 520 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
20 Inches		0 Feet	20 Feet
14-3/4 Inches		20 Feet	520 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	42	.250	0	20
10-3/4	28	.250	+ 1	500

Perforations:
Type perforation Millslot & Screen
Size perforation 3/16x3 - .50 slot
From 260 feet to 480 feet
From Alternate feet to perforated feet
From and screen feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured

Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 500 feet

9. WATER LEVEL
Static water level 126 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hackworth Drilling, Inc. (Contractor)
Address P. O. Box 850 (Contractor)
Elko, NV 89803 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1998
Signed Bradley D. Wiesl
By driller performing actual drilling on site or contractor
Date May 8, 2002

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627