WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88588
Permit No.
Basin 037

NOTICE OF INTENT NO. 40220

1. OWNER Danny Betancourt
MAILING ADDRESS 1836 Sawyer Way
ELKO, NV. 89801
ADDRESS AT WELL LOCATION Gold Creek

2. LOCATION SE ¼ SW ¼ Sec. 32 T. 45 N/S R. 56 E. ELKO County
PERMIT NO. (Issued by Water Resources) Parcel No. 2 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Volcanic tuffs and Volcanic flows		0'	240'	
	160'-180'			
2 Hrs. of cleaning				
water is clean				

Date started 9-16-02 19
Date completed 9-18-02 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
8		

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12	0	20'
10½	20'	240'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6⅝	12.75	.188	0'	240'

Perforations:
Type perforation Vert. Slot
Size perforation ⅛" .125
From 160' feet to 240' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 240' feet to ~~150~~ 50' feet

9. WATER LEVEL
Static water level 98' feet below land surface
Artesian flow -ND G.P.M. P.S.I.
Water temperature 51° °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ward Weaver
Address 2305 Last Chance Rd. (Contractor)
ELKO, NV. 89801 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0030630
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1676
Signed Ward Weaver (By driller performing actual drilling on site or contractor)
Date 9-18-02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627