WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88590
Permit No.
Basin 105

NOTICE OF INTENT NO. 50613

1. OWNER Doug Wilson
MAILING ADDRESS 2891 Springwood Dr.
So. Lake Tahoe,, CA 96150

ADDRESS AT WELL LOCATION 1355 Dolores
Gardnerville, NV.

2. LOCATION SW 1/4 NE 1/4 Sec. 1 T 12N N/S R 19E E Douglas County
PERMIT NO. (Issued by Water Resources) 1219-01-000-018 (Parcel No.) Mottsville (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fine Gray sand	yes	6	75	69
Course Gray DG	yes	75	83	8
Fine sandy DG	yes	83	115	32
Sandy soil	no	0	6	6
Course Br. DG	yes	115	190	75
Cement plug on bottom of casing				

RECEIVED 02 SEP 24 AM 10:53 STATE ENGINEER'S OFFICE

Date started 9/16/2002, 19__
Date completed 9/20/2002, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
+-75		1 Hr.

8. WELL CONSTRUCTION
Depth Drilled 190 Feet Depth Cased 190 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 1/2 Inches	0 Feet	190 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+2	190

Perforations:
Type perforation Factory Milled
Size perforation 1/8 X 3 9 row
From 165 feet to 190 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100 ft.
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 190 feet

9. WATER LEVEL
Static water level 1 1/2 Ft. feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eddco Exploration Inc. (Contractor)
Address 7780 Curry Road (Contractor)
Fallon, NV. 89406
Nevada contractor's license number issued by the State Contractor's Board 27673A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller? 1686
Signed (By driller performing actual drilling on-site or contractor)
Date 9/21/2002

USE ADDITIONAL SHEETS IF NECESSARY