WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68599
Permit No.
Basin 107

NOTICE OF INTENT NO. 50625

1. OWNER James and Dianne Merrithew
MAILING ADDRESS Upper Coloney Rd.
Wellington,, NV

ADDRESS AT WELL LOCATION 228 Chaparral
Wellington, NV.

2. LOCATION SW 1/4 NW 1/4 Sec. 22 T 11N N/S R 24E E Lyon County
PERMIT NO. Issued by Water Resources
9-151-06 Parcel No.
Sierra Desert view Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand and gravel with	No	84		
br. clay			114	30
Fine DG	No	0	84	84
Dark Clay	No	114	177	63
Well sorted gravel	Yes	177	220	43

Date started 2/27/2003 , 19__
Date completed 2/28/2003 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35		2 hrs

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	220	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+2	220

Perforations:
Type perforation Factory Mille
Size perforation 3/16 X 3 6 row
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 ft.
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 50 feet to 220 feet

9. WATER LEVEL
Static water level 87 ft. feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eddco Exploration Inc. Contractor
Address 7780 Curry Rd. Contractor
Fallon, NV. 89406
Nevada contractor's license number issued by the State Contractor's Board 27673A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
Signed [signature] By driller performing actual drilling on-site or contractor
Date 3/1/2003

USE ADDITIONAL SHEETS IF NECESSARY