

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 88602  
 Permit No. \_\_\_\_\_  
 Basin 087  
 NOTICE OF INTENT NO. H6022

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER Guido / Bruna Pincolini ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 239 W 2<sup>ND</sup> ST 507 E 4<sup>TH</sup> ST  
Reno NV 8950 Reno NV  
 2. LOCATION NW 1/4 NW 1/4 Sec 17 T 19 R 19 E Washoe County  
 PERMIT NO. NDEP # 4-000-229 008-241-09 Parcel No. \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand, gravel + cobbles		0	18	18
Clayey sand	27/28'	18	20	2
Sand, gravels + cobbles		20	30	10
Sand with clay		30	37	7
Sand		37	40	3

8. WELL CONSTRUCTION  
 Depth Drilled 40 Feet Depth Cased 40 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8 Inches To 40 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4		Sch 40	0	25

Perforations:  
 Type perforation Factory  
 Size perforation .020  
 From 25 feet to 40 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 22  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 22 feet to 40 feet

Date started 2-22, 2003  
 Date completed 2-22, 2003

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
 Static water level 28 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Boat Langyear Contractor  
 Address PO Box 1000 Contractor  
Dayton NV 89403  
 Nevada contractor's license number issued by the State Contractor's Board 00219716  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M.2222  
 Signed Bruna Pincolini  
 By driller performing actual drilling on site or contractor  
 Date 2-23-03