

OFFICE USE ONLY  
 I No. 88628  
 Permit No. \_\_\_\_\_  
 Basin 107

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49350

1. OWNER Kenwood ADDRESS AT WELL LOCATION H. Le Londe  
 MAILING ADDRESS \_\_\_\_\_ Smith Valley  
 2. LOCATION NW 1/4 SE 1/4 Sec 29 T 10 N/S R 24 E Lyon County  
 PERMIT NO. 10-761-33 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DIRT-GRAVEL		0	14	14
FRACTURED ROCK		14	70	56
DECOMPOSED ROCK-GRAVEL	X	70	105	35
FRACTURED ROCK		105	180	75
STREAKY BROWN CLAY-GRAVEL	X	180	198	18
FRACTURED ROCK		198	243	45
STREAKY CLAY-GRAVEL	X	243	275	28

8. WELL CONSTRUCTION  
 Depth Drilled 275 Feet Depth Cased 275 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>10 5/8</u>	0	100		
<u>9 7/8</u>	100	275		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>14</u>	<u>.188</u>	<u>71</u>	<u>275</u>

Perforations:  
 Type perforation Factory milled  
 Size perforation 3/32" X 3"

From	feet to	feet	feet
<u>255</u>	<u>275</u>		
<u>195</u>	<u>195</u>		

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 100

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 100 feet to 275 feet

9. WATER LEVEL  
 Static water level 170 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality CLEAR

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Blain Drilling & Pump Co.  
P.O. Box 1255  
 Address Carson City, NV 89702  
 Contractor

Nevada contractor's license number issued by the State Contractor's Board 46498  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167  
 Signed Jack Dotson  
 By driller performing actual drilling on site or contractor  
 Date \_\_\_\_\_

Date started 17 JAN 03, 20 \_\_\_\_  
 Date completed 22 JAN 03, 20 \_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>12-15</u>		<u>1.5</u>

RECEIVED  
 13 FEB - 7 PM 11:06  
 STATE ENGINEERS OFFICE