WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88629
Permit No.
Basin 107

NOTICE OF INTENT NO. 50619

1. OWNER BDR Construction
MAILING ADDRESS 39 Wellingon Cutoff
Wellington, NV 89444

ADDRESS AT WELL LOCATION 36 Colonie Rd.
Wellington NV. 89444

2. LOCATION NW 1/4 SW 1/4 Sec. 34 T 11N N/S R 23E E Lyon County
PERMIT NO. (Issued by Water Resources) 09-142-10 (Parcel No.) Colonie Estates (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DG with some clay	No	0	13	13
Sandy DG	NO	13	175	162
DG with br. clay	NO	175	210	35
Course DG well sorted	Yes	210	240	30

Date started 12/19/~~1902~~ 2002, 19__
Date completed 12/29/2002, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
+- 25		1 Hr

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	240	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+2	240

Perforations:
Type perforation Factory Milled
Size perforation 3/16 X 3 6 Row
From 220 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100 ft
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 100 feet to 240 feet

9. WATER LEVEL
Static water level 112 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Eddco Exploration Inc. (Contractor)
Address 7780 Curry Rd (Contractor)
Fallon, NV. 89406
Nevada contractor's license number issued by the State Contractor's Board 27673A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
Signed (By driller performing actual drilling on-site or contractor)
Date 1/11/2003

USE ADDITIONAL SHEETS IF NECESSARY

2003 FEB 10 PM 12:49 STATE ENGINEERS OFFICE