

OFFICE USE ONLY
 Log No. 88631
 Permit No. _____
 Basin Ø89

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **48352**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER **EHP Corporation** ADDRESS AT WELL LOCATION **7375 Franktown Rd.**
 MAILING ADDRESS **7375 Franktown Rd.**
Washoe Valley, NV 89704

2. LOCATION **SE 1/4 SE 1/4 Sec. 22 T 16N** N/S R **19E E** **Washoe** County
 PERMIT NO. **58374 & 58375** **055-200-25**
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Domestic
 Deepen Abandon Other Municipal/Industrial

4. PROPOSED USE
 Irrigation Test Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
We tried to deepen this well. When we got to bottom of a previously deepened well, we encountered something steel. We tried to "mill" it out. We completely ruined a tricone bit with absolutely no success.				
On 12-11-02 we abandoned this well. We perforated from 140' to 85' using a Mills Knife and perforated at 1 foot intervals and 4 around. We then pumped approximately 5 yards of neat cement from bottom to top using pressure grout machine and tremie pipe. The cement was mixed 5.2 gallons of water/sack cement.				
The previous log number in Division of Water Resources for the previous deepening was #39491.				
Washoe County Permit #WL020252				
The original well log for the 8" well was not available.				

Date started **11/27/2002**, 19____
 Date completed **12/11/2002**, 19____

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

8. WELL CONSTRUCTION
 Depth Drilled **240** Feet Depth Cased **240** Feet

HOLE DIAMETER (BIT SIZE)

	From	To
7 7/8" Inches	160 Feet	240 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		.188	-2	160
6 5/8	12.9	.188	140	240

Perforations:
 Type perforation **Mills Knife**
 Size perforation **Puncture**

From	To
140 feet to	85 feet

Surface Seal: Yes No
 Depth of Seal **240**
 Placement Method: Pumped Poured
 Gravel Packed: Yes No

Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

9. WATER LEVEL
 Static water level **135** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Bruce MacKay Pump & Well Service, Inc.**
Contractor
 Address **1600 Mt. Rose Hwy**
Contractor
Reno, NV 89511
 Nevada contractor's license number issued by the State Contractor's Board **23096**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1719**
 Signed *R. Bruce MacKay*
By driller performing actual drilling on-site or contractor
 Date **12/11/02**

RECEIVED
 02 DEC 19 AM 11:10
 STATE ENGINEERS OFFICE