

MW 6

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 88633  
Permit No. 087  
Basin         

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT  
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 46037

1. OWNER Kenny Lyman ADDRESS AT WELL LOCATION 460 N Center St. Reno NV  
MAILING ADDRESS One E First St. Suite 800 County Washoe  
2. LOCATION SW 1/4 NE 1/4 Sec. 11 T. 19 N. S. R. 19 E  
PERMIT NO. WL 030008 Issued by Water Resources Parcel No. 007-298-14 Subdivision Name         

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other           
4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Silt, Ben</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>Silty Gravels Dry</u> <u>lt gray, cobbles</u>		<u>5</u>	<u>10</u>	<u>5</u>
<u>Gravels, silty</u> <u>lt gray cobbles</u>		<u>10</u>	<u>20</u>	<u>10</u>
<u>Cobbles gravels</u> <u>Dry</u>	<u>28</u>	<u>20</u>	<u>30</u>	<u>10</u>
<u>Silty clay gravels</u> <u>cobbles</u>		<u>30</u>	<u>37</u>	<u>7</u>

8. WELL CONSTRUCTION  
Depth Drilled 37 Feet Depth Cased 37 Feet  
HOLE DIAMETER (BIT SIZE)  
From 6 Inches To 0 Feet 30 Feet  
Inches Feet Feet  
Inches Feet Feet  
CASING SCHEDULE  
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)  
2          Sch 40 0 22  
Perforations:  
Type perforation Factory  
Size perforation 020  
From 22 feet to 37 feet  
From          feet to          feet  
From          feet to          feet  
From          feet to          feet  
From          feet to          feet  
Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
Depth of Seal 20  
Placement Method:  Pumped  Poured  
Gravel Packed:  Yes  No  
From 20 feet to 37 feet

Date started 1-22, 2003  
Date completed 1-22, 2003

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
Static water level 28 feet below land surface  
Artesian flow          G.P.M.          P.S.I.  
Water temperature          °F Quality         

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Boart Longyear Contractor  
Address PO Box 1000 Contractor  
Dayton NV 89403  
Nevada contractor's license number issued by the State Contractor's Board 0610157  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 17-2222  
Signed Boart Longyear  
By driller performing actual drilling on          or contractor  
Date         

RECEIVED  
FEB - 7 AM 10:51  
ENGINEERS OFFICE