WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88634
Permit No.
Basin 089

NOTICE OF INTENT NO. 48351

1. OWNER EHP Corporation
MAILING ADDRESS 7375 Franktown Rd.
Washoe Valley, NV 89704

ADDRESS AT WELL LOCATION 7375 Franktown Rd.

2. LOCATION SE 1/4 SE 1/4 Sec. 22 T 16N N/S R 19E E Washoe County
PERMIT NO. 58374 & 58375 (Issued by Water Resources) 055-200-25 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [X] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [X] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	4	4
DG, rock, boulders		4	50	46
DG & rock		50	80	30
Rock & sand		80	100	20
Hard brown rock		100	180	80
Rock & soft DG		180	220	40
Hard Fractured rock	x	220	240	20
Fractured Granite	x	240	360	120
Washoe Count Permit #WL020252				

RECEIVED 02 DEC 19 AM 11:10 STATE ENGINEERS OFFICE

Date started 12/3/2002, 19__
Date completed 12/6/2002, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	50+		3 hrs
Pump	28	10	3 hrs

8. WELL CONSTRUCTION
Depth Drilled 360 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	105	Feet
9 7/8	Inches	105	Feet	360	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+1	210
5	10.79	.188	200	360

Perforations:
Type perforation Factory
Size perforation 3/32" x 3"
From 150 feet to 210 feet
From 240 feet to 280 feet
From 320 feet to 360 feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 105
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 105 feet to 360 feet

9. WATER LEVEL
Static water level 135 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 12/11/02

USE ADDITIONAL SHEETS IF NECESSARY