


WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 51270  
 Southeast of Montello,

1. OWNER Bob Payne ADDRESS AT WELL LOCATION Nevada  
 MAILING ADDRESS P.O. Box 50, Montello, NV 89830

2. LOCATION SE 1/4 NE 1/4 Sec. 20 T. 39N N/S R. 69 E Elko County  
 PERMIT NO. 50690 Issued by Water Resources Parcel No. 010-58L-056 Tract of Land  
 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	2	2
Brown Clay		2	8	6
Gravel & Sand		8	13	5
Brown Clay		13	20	7
Brown Siltstone, some small gravel mix	55	20	70	50
Sand Gravel		70	80	10
Large Gravel		80	90	10
Brown Siltstone small gravel mix	95	90	120	30
Gray Siltstone	120	120	140	20
Green Clay	140	140	150	10
Gray/Green siltstone gravel mix		150	220	70
Gray Siltstone Small Black Gravel Mix		220	240	20
Gray Siltstone	240	240	260	20
Gray Siltstone Gravel Mix		260	280	20

8. WELL CONSTRUCTION  
 Depth Drilled 280 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)  
 From 14-3/4 Inches To 0 Feet 280 Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10		.250	+1	280

Perforations:  
 Type perforation Mill Slot  
 Size perforation 3/16 x 3  
 From 100 feet to 140 feet  
 From 160 feet to 180 feet  
 From 200 feet to 220 feet  
 From 240 feet to 280 feet  
 From        feet to        feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 280 feet

9. WATER LEVEL  
 Static water level 42 feet below land surface  
 Artesian flow        G.P.M.        P.S.I.  
 Water temperature C °F Quality       

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Hackworth Drilling, Inc. Contractor  
 Address P. O. Box 850 Contractor  
Elko, NV 89803  
 Nevada contractor's license number 020582  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1689  
 Division of Water Resources, the on-site driller  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date       

Date started 11/18/02, 19.....  
 Date completed 11/19/02, 19.....

7. WELL TEST DATA

TEST METHOD:  Baïer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
350		6

RECEIVED  
 03 JAN 21 PM 1:07  
 STATE ENGINEERS OFFICE