

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 88655

Log No. _____
 Permit No. _____
 Basin 101

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 51008

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER KOPAS KONSTRUCTION ADDRESS AT WELL LOCATION 6360 WEST WIND WAY
 MAILING ADDRESS P. O. BOX 8224
FALLON, NV 89407

2. LOCATION NE 1/4 SE 1/4 Sec. 19 T 19 N/S R 28 E CHURCHILL County
 PERMIT NO. _____ Issued by Water Resources _____ Parcel No. 8-152-23 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
BROWN SAND		1	20	19
BROWN CLAY		20	25	5
BROWN SAND		25	58	33
BROWN CLAY		58	60	2
GREY SAND		60	80	20
BROWN SILT		80	100	20
GREY SAND		100	120	20
GREY GRAVELS		120	140	20
BROWN CLAY/SAND	X	140	160	20

8. WELL CONSTRUCTION

Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>10 3/4</u> Inches	<u>0</u> Feet	<u>50</u> Feet
<u>6 1/8</u> Inches	<u>50</u> Feet	<u>160</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>+2</u>	<u>160</u>

Perforations:
 Type perforation MACHINE SLOT
 Size perforation .080

From	To
<u>154</u> feet to	<u>158</u> feet
_____ feet to	_____ feet
_____ feet to	_____ feet
_____ feet to	_____ feet
_____ feet to	_____ feet

Surface Seal: Yes No
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 Seal Type:
 Neat Cement Cement Grout Concrete Grout

9. WATER LEVEL
 Static water level 26.4 feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WELSCO CORP. Contractor
 Address P. O. BOX 888 Contractor

FALLON, NV 89406
 Nevada contractor's license number issued by the State Contractor's Board 11752
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 1/27/2003

Date started 12/26/2002 19____
 Date completed 1/10/2003 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>		<u>1 HR</u>

RECEIVED
 03 JAN 29 AM 10:53
 STATE ENGINEERS OFFICE